RESOLUTION ROCK COUNTY BOARD OF SUPERVISORS

General Services Committee INITIATED BY

General Services Committee SUBMITTED BY



Brent Sutherland DRAFTED BY

March 9, 2018 DATE DRAFTED

Authorizing the Upgrade to the Honeywell Controllers at the Rock County Jail

1	WHEREAS, the 1986 Honeywell Building Automation System controllers are in need of upgrading; and,
2	WHEREAS, the funds are available in 2018 budget to upgrade Air Handling Units 3, 4, 6 & 8; and,
4	WITTEN A C. I
5 6	WHEREAS, the system components are proprietary, obsolete, and no longer available; and,
7	WHERAS, a failure of these controllers, will affect the building HVAC systems and smoke dampers
8	controls during a fire situation.
9	
10	NOW, THEREFORE, BE IT RESOLVED that the Rock County Board of Supervisors duly assembled
11	this Mach, 2018, that a purchase order be issued to Honeywell Building
12	Solutions in the amount of \$21,585, for the required engineering, equipment, installation, setup,
13	programming for the Honeywell Controller.
14	
15	BE IT FURTHER RESOLVED, that a \$3,000 contingency also be approved to cover any possible
16	unforeseen items.
	Respectfully submitted,
	GENERAL SERVICES COMMITTEE

Henry Brill, Chair

Jeremy Zajao, Vice Chair

Dave Homan

Bob Yeomans

J. Russell Podzilini

Authorizing the Upgrade to the Honeywell Controllers at the Rock County Jail Page 2

FISCAL NOTE:

Sufficient funds were included in the budget for the upgrading of jail controllers. This project is being funded with sales tax revenue.

Sherry Oja
Finance Director

LEGAL NOTE:

The County Board is authorized to take this action pursuant to secs. 59.01 and 59.51, Wis. Stats.

Richard Greenlee Corporation Counsel

ADMINISTRATIVE NOTE:

Recommended.

Josh Smith County Administrator

EXECUTIVE SUMMARY

UPGRADE THE HONEYWELL CONTROLLER AT THE JAIL

The resolution before you authorizes the upgrade of the controller for Air Handling Units 3, 4, 6 & 8 at the Jail. These controllers control the HVAC system as well as the smoke dampers in a fire situation to prevent the spread of smoke. These controllers are part of the building automation system that receives the programming from the head end system. This is proprietary equipment.